


[Return to Previous Page](#)

Help for this report: This report contains most of the data from the facility record including inspections, MITs, permit information and project status. You can select/copy and "paste special- unformatted text" all or part of this page to a text document to start correspondence about the facility.

Facility

Elder Drainfield
no data
Grand Ronde, OR 97347

GIS: 45.07689, -123.61836
Local Identifier: none
UIC Facility ID: OR141T5-97-10910
Tribal Land: Grand Ronde
Ownership:

Contacts

Contact Type: Operator
Eric Scott
Grand Ronde Tribal Engineer
9615 Grand Ronde Road
Grand Ronde, OR 97347
email: eric.scott@grandronde.org

Well Summary

12 - Active - 5W12 Wastewater Treatment Plant Effluent Injection - as of 11/03/2009

Named Wells

Well Name	Operating Status	Status Date	R10 Well Type Name	Well Type Date
Elder Drainfield : 012 - Active	-	11/03/2009	- 5W12 Wastewater Treatment Plant Effluent Injection -	11/03/2009
Elder Drainfield : 011 - Active	-	11/03/2009	- 5W12 Wastewater Treatment Plant Effluent Injection -	11/03/2009
Elder Drainfield : 010 - Active	-	11/03/2009	- 5W12 Wastewater Treatment Plant Effluent Injection -	11/03/2009
Elder Drainfield : 009 - Active	-	11/03/2009	- 5W12 Wastewater Treatment Plant Effluent Injection -	11/03/2009
Elder Drainfield : 008 - Active	-	11/03/2009	- 5W12 Wastewater Treatment Plant Effluent Injection -	11/03/2009
Elder Drainfield : 007 - Active	-	11/03/2009	- 5W12 Wastewater Treatment Plant Effluent Injection -	11/03/2009
Elder Drainfield : 006 - Active	-	11/03/2009	- 5W12 Wastewater Treatment Plant Effluent Injection -	11/03/2009
Elder Drainfield : 005 - Active	-	11/03/2009	- 5W12 Wastewater Treatment Plant Effluent Injection -	11/03/2009
Elder Drainfield : 004 - Active	-	11/03/2009	- 5W12 Wastewater Treatment Plant Effluent Injection -	11/03/2009
Elder Drainfield : 003 - Active	-	11/03/2009	- 5W12 Wastewater Treatment Plant Effluent Injection -	11/03/2009
Elder Drainfield : 002 - Active	-	11/03/2009	- 5W12 Wastewater Treatment Plant Effluent Injection -	11/03/2009
Elder Drainfield - Active	-	11/03/2009	- 5W12 Wastewater Treatment Plant Effluent Injection -	11/03/2009

Other Ground Water Considerations For Facility

No Non-UIC Discharges recorded.

Inspections in the last 10 Years

No inspections recorded in iWells database over the last 10 years.

Mechanical Integrity Tests

No mechanical integrity tests found.

Permit & Permit Activity

No permit or permit activity found.

Violations

No violations found.

Enforcement Actions

No enforcement actions found.

Attachments

no data found.

Project Status and Comments

Followup Date ▼	Status	Action Date	Last Update	Action Needed	First Mid	Last Comments	Comments Overflow	Username
-	Inventory Only	08/21/0009	12/13/2012 -	-	-	Drainfield is pressure distributed with approximately 12 zones. The drainfield has 1-1/4" laterals with 1/8" holes at 2' centers. The holes are upward pointing with orifice shields and filter fabric over them under the backfill. The drainfield design was done by the Tribal Engineer, P.E. Eric Scott. An Oregon State sanitarian did the soil study and determined appropriate loading rates.	-	JPARKER
-	Other	08/21/2009	12/13/2012 -	-	-	Elder Drainfield is the common name for the drainfield located near the tribal elder housing. At the time of the UIC inventory visit on August 18, 2009, the elder drainfield was finished being constructed, but not yet in use. When put into use, the drainfield should receive effluent from an MBR plant serving the elder housing and the tribal campus (government buildings). 3 pictures taken on August 18, 2009 are saved as: Elder_Drainfield_Aug-09.	-	JPARKER

Reference Key

Key	Facility	Added By
5011	Elder Drainfield	JPARKER